

## **City of Auburn: 2022 –TFHP-36014**

HVAC Specs: Approved by the Nebraska Department of Environment & Energy (NDEE)

- \* 80,000 BTUH Carrier 96% single-stage gas furnace
- \* 1.5 ton Carrier 14 SEER single stage A/C
- \* Programable Thermostat
- \* Venting of exhaust fans
- \* Honeywell fresh air ventilation Y8150A1017
- \* Ductwork throughout house
- \* Grilles/Registers
- \* Startup and testing
- \* Powered Humidifier