

BOARD OF PUBLIC WORKS

CITY OF AUBURN, NE
ELECTRIC, WATER & WASTEWATER SERVICES

BOARD MEMBERS

Charles Knipe
Richard L. Wilson
Dr. Michael Zaruba
David Grant
Phil Shaw



GENERAL MANAGER

Ray Luhring

Phone: (402) 274-4981 Office
(402) 274-3316 After Hour
(402) 274-4991 Fax

DROUGHT CONTINGENCY PLAN UPDATE

March 28, 2025

The Board of Public Works continues working diligently to make sure water levels remain stable. We continue to provide data with daily readings on the number of gallons pumped, pumping times, and reservoir levels. This will keep the public informed of current conditions. See the City of Auburn website at <https://auburn.ne.gov> for updates.

If you have questions about the status of any of our activities, please contact the BPW and we are happy to provide you with statistics of rainfall, well levels and daily monitoring of the water pumped. All systems are actively monitored, and data is kept on file permanently. The reservoir holds 1.5 million gallons of water and has not dropped below the normal levels. This is due to the implementation of the plan and the collaboration of the members of the Auburn and Peru communities' reduction in use.

We appreciate all efforts for conserving usage until levels return to normal.

Alan Slater
Water/Wastewater Manager

BOARD OF PUBLIC WORKS

CITY OF AUBURN, NE
ELECTRIC, WATER & WASTEWATER SERVICES

BOARD MEMBERS

Charles Knipe
Richard L. Wilson
Dr. Michael Zaruba
David Grant
Phil Shaw



GENERAL MANAGER

Ray Luhring
Phone: (402) 274-4981 Office
(402) 274-3316 After Hour
(402) 274-4991 Fax

Auburn Board of Public Works - Updated Daily readings

Date	Total # of Gallons pumped	Auburn plant GPM pumped	Total # of hours pumped	# of Gallons pumped Auburn	# of Gallons pumped Peru	GPM Pumped Peru	# of hours pumped Peru
10/17/2024	624,558	600	17.34	498,695	125,863	90	23.30
10/18/2024	424,698	600	11.79	354,226	,70,472	90	13.05
02/19/2025	563,203	600	15.64	448,091	115,112	90	21.32
02/20/2025	526,889	600	14.64	468,142	58,747	90	10.88
02/21/2025	592,422	600	16.46	478,359	114063	90	21.12
02/22/2025	411,012	600	11.42				
02/23/2025	526,622	600	14.63				
02/24/2025	753,200	600	20.92	632,588	120,612	90	22.34
02/25/2025	550,251	600	15.28	476,689	73,562	90	13.62
02/26/2025	499,481	600	13.87	382,412	117,069	90	21.68
02/27/2025	483,334	600	13.43	374,364	108,970	90	20.18
02/28/2025	389,935	600	10.83	288,261	101,674	90	18.83
03/01/2025	597278	600	16.59				
03/02/2025	444,008	600	12.33				
03/03/2025	454,298	600	12.62	381,929	72,369	90	13.4
03/04/2025	566,087	600	15.72	443,687	122,400	90	22.7
03/05/2025	524,072	600	14.55	418,639	105,433	90	19.52
03/06/2025	535,007	600	14.86	439,806	95,201	90	17.62
03/10/2025	411,283	600	11.42	319,144	92,139	90	17.06
03/11/2025	456,440	600	12.67	358,190	98,250	90	18.19
03/12/2025	365,446	600	10.15	286,625	78,821	90	14.59
03/13/2025	383,292	600	10.65	314,110	69,182	90	12.81
03/14/2025	553,483	600	15.37	460776	92,707	90	17.16
03/17/2025	452,873	600	12.58			90	
03/18/2025	470,188	600	13.06	355,136	115,052	90	21.30
03/19/2025	414,701	600	11.52	330,962	83,739	90	15.50
03/20/2025	553,078	600	15.36	445,917	107,161	90	19.84
03/21/2025	418,361	600	11.62	301,530	116,831	90	21.63
03/24/2025	499,517	600	13.87	427,506	72,011	90	13.33
03/25/20205	541,349	600	15.04	418,678	122,671	90	22.72
03/26/2025	525,074	600	14.6	406,146	118,928	90	22.02
03/27/2025	409,172	600	11.37	292,833	116,339	90	21.54
03/28/2025	381,983	600	10.61	267,095	114,888	90	21.27

BOARD OF PUBLIC WORKS

CITY OF AUBURN, NE
ELECTRIC, WATER & WASTEWATER SERVICES

BOARD MEMBERS

Charles Knipe
Richard L. Wilson
Dr. Michael Zaruba
David Grant
Phil Shaw



GENERAL MANAGER

Ray Luhring
Phone: (402) 274-4981 Office
(402) 274-3316 After Hour
(402) 274-4991 Fax

Reservoir levels							
03/16/2025	22'	Full		03/27/2025	22'	Full	
03/17/2025	22'	Full		03/28/2025	22'	Full	
03/18/2025	22'	Full					
03/21/2025	22'	Full					
03/24/2025	22'	Full					
03/25/2025	22'	Full					

Pumping well levels are monitored by measuring water levels above the top of screens in the well when the well is running. Normal water levels run 15-20 feet above the screens. The following data shows the amount of water measured above the screens.

	Well 1	Well 2	Well 3	Well 4	Well 5	Well 6	Well 11	Well 13	Well 19	Well 20
10/22/2024	9'	9'	2'	1'	6.5'	5'	5'	16'	2'	1'
02/24/2025	14'	11'	10'	8'	8'	7'	6'	11'	4'	4'5"
02/25/2025	14'	11'	10'	8'	7'	8'	9'	11'	4'	4'5"
02/26/2025	14'	11'	10'	8'	7'	8'	9'	11'	4'	4'5"
02/27/2025	14'	11'	10'	8'	7'	8'	9'	11'	4'	4'5"
02/28/2025	14'	11'	10'	8'	7'	8'	9'	11'	4'	4'5"
03/03/2025	14'	11'	10'	8'	7'	8'	9'	11'	4'	4'5"
03/04/2025	14'	11'	10'	7'	6'	8'	9'	11'	5'	4'
03/07/2025	14'	11'	10'	7'	6'	8'	9'	11'	5'	4'
03/10/2025	14'	11'	10'	7'	6'	8'	9'	11'	5'	4'
03/11/2025	14'	11'	10'	7'	6'	8'	9'	11'	5'	4'
03/12/2025	14'	11'	10'	7'	6'	8'	9'	11'	5'	4'
03/14/2025	14'	11'	10'	7'	6'	8'	9'	11'	5'	4'
03/17/2025	15'7"	12'	10'	8'	7'	9'	9'	12'	5'	5'
03/18/2025	15'	12'	9'	8'	6'	8'	9'	12'	5'	5'
03/21/2025	15'	12'	9'	8'	6'	8'	9'	12'	5'	5'
03/24/2025	15'	12'	9'	8'	6'	8'	9'	12'	5'	5'
03/25/2025	15'	12'	9'	7'	6'	7'	9'	12'	5'	4'5"
03/26/2025	15'	12'	9'	7'	6'	7'	9'	12'	5'	4'5"
03/27/2025	15'	12'	9'	7'	6'	7'	9'	12'	5'	4'5"
03/28/2025	14'8"	11'	7'4"	7'	5'	6'8"	8'	11'	4'4"	4'