

# BOARD OF PUBLIC WORKS

CITY OF AUBURN, NE  
ELECTRIC, WATER & WASTEWATER SERVICES

## BOARD MEMBERS

Charles Knipe  
Richard L. Wilson  
Dr. Michael Zaruba  
David Grant  
Phil Shaw



## GENERAL MANAGER

Ray Luhring

Phone: (402) 274-4981 Office  
(402) 274-3316 After Hour  
(402) 274-4991 Fax

## DROUGHT CONTINGENCY PLAN UPDATE

May 14, 2025

Stage 3 Drought Contingency Protocol is still in place. There are some misconceptions that are being shared. At this time any non – essential water use is prohibited. Businesses are allowed to operate as needed but asked to conserve water in any capacity that they can.

At this time reservoir levels are stable, and wells are able to keep up with demand. We do have emergency water resources prepared to be trucked in if the reservoir is unable to maintain necessary levels for residential and commercial customers. Short-term solutions for collection are in process and long-term solutions are being researched.

A special meeting was held to move forward with a project for a short-term solution and a proposed ordinance was recommended to the City of Auburn for approval. The community was able to present ideas and concerns. The Board is reviewing the information and will be moving forward on projects as they are able to.

The restrictions are not meant to punish the community, but rather an effort to be good stewards of the resources that are currently available to all our customers, so that drastic measures can be avoided. We appreciate all of our customers and work hard to ensure that water is safe and available. We continue to provide data with daily readings on the number of gallons pumped, pumping times, and reservoir levels. This will keep the public informed of current conditions. See the City of Auburn website at <https://auburn.ne.gov> for updates.

If you have questions about the status of any of our activities, please contact the BPW and we are happy to provide you with statistics of rainfall, well levels and daily monitoring of the water pumped. All systems are actively monitored, and data is kept on file permanently. The reservoir holds 1.5 million gallons of water and has not dropped below the normal levels. This is due to the implementation of the plan and the collaboration of the members of the Auburn and Peru communities' reduction in use. We appreciate all efforts for conserving usage until levels return to normal.

Alan Slater  
Water/Wastewater Manager

Auburn Board of Public Works - Updated Daily readings.

# BOARD OF PUBLIC WORKS

CITY OF AUBURN, NE  
ELECTRIC, WATER & WASTEWATER SERVICES

## BOARD MEMBERS

Charles Knipe  
Richard L. Wilson  
Dr. Michael Zaruba  
David Grant  
Phil Shaw



## GENERAL MANAGER

Ray Luhring

Phone: (402) 274-4981 Office  
(402) 274-3316 After Hour  
(402) 274-4991 Fax

Date	Total # of Gallons pumped	Auburn plant GPM pumped	Total # of hours pumped	# of Gallons pumped Auburn	# of Gallons pumped Peru	GPM Pumped Peru	# of hours pumped Peru
10/17/2024	624,558	600	17.34	498,695	125,863	90	23.30
10/18/2024	424,698	600	11.79	354,226	,70,472	90	13.05
04/08/2025	506,158	600	14.06	430,591	75,567	90	13.99
04/11/2025	369,467	600	10.26	298,818	70,649	90	13.08
04/14/2025	520,577	600	14.46	445,429	78,148	90	14.47
04/15/2025	490,760	600	13.63	385,962	104,798	90	19.41
04/16/2025	474,297	600	10.26	398,818	76,048	90	14.08
04/17/2025	427,715	600	11.88	320,731	106,984	90	19.81
04/18/2025	450,414	600	12.51	380,228	70,186	90	13.00
04/19/2025	557,254	600	15.48	461,548	95,706	90	17.72
04/20/2025	391,007	600	10.86	306,513	84,494	90	15.65
04/21/2025	391,417	600	10.87	329,276	62,141	90	11.51
04/22/2025	481,344	600	13.37	375,666	105,678	90	19.57
04/23/2025	440,564	600	12.24	362,560	78,004	90	14.45
04/24/2025	385,121	600	10.70	309,542	75,579	90	14.00
04/25/2025	397,665	600	11.05	291,529	105,597	90	19.56
04/26/2025	463,451	600	12.87	391,754	71,697	90	13.27
04/27/2025	455,804	600	12.66	393,133	62,671	90	11.61
04/28/2025	402,395	600	11.18	185,969	116,426	90	21.56
04/29/2025	258,480	600	7.18	188,963	69,517	90	12.87
04/30/2025	470,330	600	13.06	368,968	101,692	90	18.77
05/01/2025	393,649	600	10.94	324,287	69,362	90	12.85
05/02/2025	512,489	600	14.24	442,529	69,960	90	12.96
05/03/2025	496,949	600	13.8	445,909	51,040	90	9.45
05/04/2025	526,590	600	14.63	421,807	104,773	90	19.40
05/05/2025	385,445	600	10.71	308,510	76,935	90	14.25
05/06/2025	377,717	600	10.49	325,067	52,650	90	9.75
05/07/2025	458,978	600	12.75	380,599	78,379	90	14.51
05/08/2025	436,209	600	12.12	350,955	85,254	90	15.79
05/09/2025	440,023	600	12.22	382,564	57,459	90	10.64
05/10/2025	515,344	600	14.32	457,757	57,587	90	10.66
05/11/2025	535,056	600	14.86	450,654	84,402	90	15.63
05/12/2025	426,803	600	11.86	351,581	75,222	90	13.93
05/13/2025	325,961	600	9.05	274,482	51,479	90	9.53
05/14/2025	429,974	600	11.94	371,975	57,999	90	10.74

# BOARD OF PUBLIC WORKS

CITY OF AUBURN, NE  
ELECTRIC, WATER & WASTEWATER SERVICES

## BOARD MEMBERS

Charles Knipe  
Richard L. Wilson  
Dr. Michael Zaruba  
David Grant  
Phil Shaw



## GENERAL MANAGER

Ray Luhring

Phone: (402) 274-4981 Office  
(402) 274-3316 After Hour  
(402) 274-4991 Fax

Reservoir levels							
04/27/2025	22'	Full		05/08/2025	22'	Full	
04/28/2025	22'	Full		05/12/2025	22'	Full	
05/01/2025	22'	Full		05/13/2025	22'	Full	
05/06/2025	22'	Full		05/14/2025	22'	Full	
05/07/2025	22'	Full					

Pumping well levels are monitored by measuring water levels above the top of screens in the well when the well is running. Normal water levels run 15-20 feet above the screens. The following data shows the amount of water measured above the screens.

	Well 1	Well 2	Well 3	Well 4	Well 5	Well 6	Well 11	Well 13	Well 19	Well 20
10/22/2024	9'	9'	2'	1'	6.5'	5'	5'	16'	2'	1'
02/28/2025	14'	11'	10'	8'	7'	8'	9'	11'	4'	4.5'
03/17/2025	15.7'	12'	10'	8'	7'	9'	9'	12'	5'	5'
04/03/2025	14'8"	11'	5'2"	5'5"	4'3"	6'8"	8'	10'	3'4"	3'6"
04/04/2025	14'8"	11'	5'2"	5'5"	4'4"	6'8"	8'	10'	3'4"	3'6"
04/07/2025	14'8"	11'	5'2"	5'5"	4'4"	6'8"	8'	10'	3'4"	3'6"
04/08/2025	14'8"	11'	5'2"	5'5"	4'4"	6'8"	8'	10'	3'4"	3'6"
04/09/2025	15'	12'	5'6"	5'7"	4'8"	6'5"	8'	11'	4'	4'
04/10/2025	15'	12'	5'6"	5'7"	4'8"	6'5"	8'	11'	4'	4'
04/11/2025	15'	12'	6'1"	5'8"	4'8"	6'5"	8'	11'9"	4'	4'
04/14/2025	15'	12'	6'1"	5'8"	4'8"	6'5"	8'	11'9"	4'	4'
04/15/2025	15'	12'	6.1'	5.8'	4'8"	6'5"	8'	11'9"	4'	4'
04/16/2025	14'8"	11'7"	6'1"	5'8"	4'8"	6'5"	8'	11'8"	4'	4'
04/17/2025	14'8"	11'7"	6'1"	5'8"	4'8"	6'8"	8'	11'8"	4'	4'
04/22/2025	14'8"	11'7"	6'1"	5'8"	4'8"	6'5"	8'	11'8"	4'	4'
04/24/2025	15'	12'	4'7"	5'4"	5'1"	6'3"	8'	11'	3'9"	4'
04/25/2025	15'	12'	4'7"	5'4"	5'1"	6'3"	8'	11'	3'9"	4'
04/28/2025	15'	12'	4'7"	5'4"	5'1"	6'3"	8'	11'	3'9"	4'
05/01/2025	14'9"	11'6'	4'7"	5'4"	5'1'	6'3"	7'9"	11'	3'9"	4'
05/06/2025	14'	11'	4'2"	4'9"	4'7"	6'9"	7'	11'	3'4"	3'8"
05/07/2025	14'	11'	4'2"	4'9"	4'3.5"	6'	5'8"	10'5"	3'9"	4'
05/08/2025	14'	11'	4'2"	4'9"	4'7"	6'9"	7'	11'	3'4"	3'8"
05/09/2025	14'	11'	4'2"	4'9"	4'7"	6'9"	7'	11'	3'4"	3'8"
05/12/2025	14'	11'	4'2"	4'9"	4'7"	6'9"	7'	11'	3'4"	3'8"
05/13/2025	14'	11'	4'2"	4'9"	4'7"	6'9"	7'	11'	3'4"	3'8"
05/14/2025	14'	11'	4'2"	4'9"	4'6"	6'9"	7'	11'	3'4"	3'8"